

PRODUCT DATA SHEET

Ultracool UC 24

LAUDA Ultracool circulation chillers provide precise temperature control in an extended operating temperature range from -10 to 35 °C and a temperature stability of ± 0.5 K. The protection class IP 54 enables outdoor installation, a standard fan control enables operation at ambient temperatures down to -15 °C and reduces noise pollution. LAUDA has been able to reduce the footprint even further compared to comparable previous models. The circulation chillers have an Ethernet interface as standard and can be adapted to any customer-specific requirement thanks to numerous options such as speed-controlled pumps or flow meters. The bifrequency power supply (50/60 Hz) allows the same model types to be used worldwide.



Working temperature min.
-10 °C



Working temperature max.
35 °C

Technical Attributes

Ultracool UC 24

Working temperature min.	-10 °C
Working temperature max.	35 °C
Ambient temperature min.	-15 °C
Ambient temperature max.	50 °C
Temperature stability	0.5 \pm K
Cooling output at 25°C water outlet temperature	34.0 kW
Cooling output at 20°C water outlet temperature	30.9 kW
Cooling output at 15°C water outlet temperature	28.1 kW
Cooling output at 10°C water outlet temperature	24.3 kW
Cooling output at 5°C water outlet temperature	20.8 kW
Cooling output at 0°C water outlet temperature	17.3 kW
Cooling output at -5°C water outlet temperature	14.5 kW
Cooling output at -10°C water outlet temperature	12.0 kW
Number of refrigeration circuits	1
Application	external

LAUDA DR. R. WOBSEY GMBH & CO. KG
Pfarrstraße 41/43 · 97922 Lauda-Königshofen
Postfach 1251 · 97912 Lauda-Königshofen · DE

T +49 (0) 9343 503-0 · F +49 (0) 9343 503-222
info@lauda.de · www.lauda.de
WEEE-Reg.-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
Registergericht Mannheim · HRA 560069

Persönlich haftende Gesellschafterin:
LAUDA DR. R. WOBSEY Verwaltungs-GmbH
Sitz Lauda-Königshofen
Registergericht Mannheim · HRB 560226

Geschäftsführer:
Dr. Gunther Wobser (Vors.), Dr. Mario Englert
Dr. Marc Stricker
Beirat: Dr. Gerhard Wobser

PRODUCT DATA SHEET

Ultracool UC 24

Technical Attributes	Ultracool UC 24
Power consumption	8.0 kW
Pump pressure max.	4.2 bar
Pump pressure nominal	2.7 bar
Pump flow max. (pressure)	130 L/min
Pump flow nominal	84.1 L/min
Pump connection thread	Rp 1
Volume water reservoir	35 L
Dimensions (WxDxH) in mm	720x910x1250
Noise level	64.7 dB(A)
Max. fuse	32 A

LAUDA DR. R. WOBSEY GMBH & CO. KG
 Pfarrstraße 41/43 · 97922 Lauda-Königshofen
 Postfach 1251 · 97912 Lauda-Königshofen · DE

T +49 (0) 9343 503-0 · F +49 (0) 9343 503-222
 info@lauda.de · www.lauda.de
 WEEE-Reg.-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
 Registergericht Mannheim · HRA 560069

Persönlich haftende Gesellschafterin:
 LAUDA DR. R. WOBSEY Verwaltungs-GmbH
 Sitz Lauda-Königshofen
 Registergericht Mannheim · HRB 560226

Geschäftsführer:
 Dr. Gunther Wobser (Vors.), Dr. Mario Englert
 Dr. Marc Stricker
 Beirat: Dr. Gerhard Wobser