

AHEAD OF THE FLOW®

# **Bronze Ball Valves**



Three-Piece Body • Full Port • Copper Stub Ends • Type K (straight) • Type L (expanded) • Cleaned and Bagged for OX Service • Bronze Trim • Blowout-Proof Stem

## 600 PSI/41.4 bar non-shock cold working pressure 200 PSI/13.8 bar for medical gas

CONFORMS TO MSS SP-110

### MATERIAI LIST

MAI EKIAL LIST										
PART	SPECIFICATION									
Handle Nut	Zinc Plated Steel									
Handle	Zinc Plated Steel Clear Chromate Plastisol Coated									
Threaded Pack Gland	Brass ASTM B 16 Alloy C36000									
Stem	Silicon Bronze ASTM B 371 Alloy C69430 or ASTM B 99 Alloy C65100									
Body	Bronze ASTM B 584 Alloy C84400									
Packing	PTFE									
Body End (2)	Bronze ASTM B 584 Alloy C84400									
O-Ring Seal (2)	Fluoroelastomer Rubber									
Seat Ring (2)	PTFE									
Ball	Brass ASTM B 124 Alloy C37700 or ASTM B16 Alloy C36000 EACH with Hard Chrome Plate									
Ground Washer	Stainless Steel ASTM A 167 Type 304									
Thrust Washer	Reinforced PTFE									
Body Bolts	Zinc Dichromate Plated Steel ASTM A 449 Grade 5									
Body Nuts	Zinc Dichromate Plated Steel ASTM A 449 Grade 5									
Straight Stub Out (2)	6" Copper Tube Type K									
Expanded Stub Out (2)	6" Copper Tube Type L (Specify EC)									
	PART Handle Nut Handle Threaded Pack Gland Stem  Body Packing Body End (2) O-Ring Seal (2) Seat Ring (2) Ball Ground Washer Thrust Washer Body Bodts  Body Nuts  Straight Stub Out (2)									

Note: valves are static grounded by a grounding washer. (not shown)

#### **Testing**

The CS-595-YX series are tested to MSS SP-110. For applications that require a 150 PSI dry nitrogen test, please contact NIBCO Technical Services.

MSS SP-110 Test parameters are as follows:

Shell Test = 80 PSI air under water for 5 seconds or 1.5 x CWP hydrostatic for 15 seconds.


Seat Test = 80 PSI air under water for 5 seconds or 1.1 CWP hydrostatic for 15 seconds.


NIBCO's internal cleaning procedure for cleaned and bagged bronze ball valves meets the requirements of NFPA99 and CGA Pamphlet G-4-1.

### **Medical Gas Service**

NFPA 99 sets a maximum operating limit for medical gases of 185 PSI.







**DIMENSIONS—WEIGHTS—QUANTITIES** 

Dimensions																	
Size		Α		В		С		D		F		G		Н		5-YX/EC	Master
In.	mm.	ln.	mm.	ln.	mm.	ln.	mm.	ln.	mm.	In. mm.	ln.	mm.	ln.	mm.	Lbs.	Kg.	Ctn. Qty.
1/2	15	.50	13	1.69	43	1.81	46	1.11	28	13.11 333	3.9	1 99	.50	13	1.22	.55	10
3/4	20	.75	19	2.00	51	1.94	50	1.41	36	13.41 34°	4.6	3 118	.75	19	2.25	1.02	10
1	25	1.00	25	2.25	57	2.50	64	1.81	46	13.81 35°	4.6	3 118	.91	23	3.23	1.47	10
1 1/4	32	1.25	32	2.75	70	2.69	68	1.96	50	13.96 35	6.6	9 170	.97	25	4.41	2.00	4
1 ½	40	1.50	38	2.97	75	3.00	76	2.39	61	14.39 366	6.6	9 170	1.09	28	6.61	3.00	4
2	50	2.00	51	3.63	92	4.00	102	3.04	77	15.04 382	6.6	9 170	1.34	34	11.67	5.29	4

and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

WARNING: This product can expose you to chemicals including lead, which is known to the State of California to cause cancer





Visit our website for the most current information.