



Series FS1-W and FS6-W Flow Switch Seal Interface Replacement

For Models with an O-Ring Groove in the Switch Housing:



For Models with a Flat Surface Switch Housing:



IMPORTANT: Do not use both the O-Ring and the Gasket for seal replacement. Using both will prevent the Flow Switch from operating.



Xylem Inc. 8200 N. Austin Avenue Morton Grove, Illinois 60053 Phone: (847) 966-3700 Fax: (847) 965-8379 www.xyleminc.com/brands/mcdonnellmiller

McDonnell & Miller is a trademark of Xylem Inc. or one of its subsidiaries. © 2013 Xylem Inc. MM-612B February 2013 Part No. 210329