


MAGNA 1 and MAGNA 3

Addendum to Safety Instructions



- 1) The pump can be used for pumping water/glycol mixtures up to 50%.
- 2) Conforms to ANSI/UL Standard 778.
- 3) Certified to CAN/CSA Standard C22.2 No. 108.
- 4) If rigid conduit is to be used, the hub must be connected to the conduit system before it is connected to the terminal box of the pump.
- 5) The protective earth (ground) symbol  identifies any terminal which is intended for connection to an external conductor for protection against electrical shock in case of a fault, or the terminal of a protective earth (ground) electrode
- 6) GRUNDFOS HOLDING A/S
CONTAINS FCC ID: OG3-RADIOM01-2G4
This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation of the device.



98477478 0513

ECM: 1114411
