




DWG NO.
DERK04

2nd RUN CAPACITOR
(IF USED)

RUN CAPACITOR

CONDUCTOR (SEE NOTE #2)

CONDUCTOR
(SEE NOTE #2)

START (U)
A

RUN (V)

COMMON (W)

NUT

PROTECTIVE
COVER

GASKET

NOTE:

1. ASSEMBLE PARTS AS SHOWN AS SPECIFIED ON B/M.
2. IDENTIFIED CONDUCTOR MAY BE WHITE OR RIBBED.
3. IF TWO RUN CAPACITORS ARE REQUIRED HOOKUP AS SHOWN.
4. COMPRESSOR UNIT GROUND LOCATED ON THE ACCUMULATOR STRAP OF THE COMPRESSOR.
5. GROUND SCREW IS NOT PROVIDED BY TECUMSEH PROD. CO.
- ▲ 6. MUST COMPLY WITH T.P.CO. GLOBAL SPEC 08.

WARNING

WIRING DIAGRAM MUST BE FOLLOWED AS SHOWN. ANY MISWIRING
CAN CAUSE SERIOUS ELECTRICAL HAZARD AND POTENTIAL DAMAGE
OR RUPTURE OF COMPONENT ELECTRICAL PARTS.

LINE

IDENTIFIED CONDUCTOR
(NEUTRAL)

GROUNDING
CONDUCTOR
GREEN

COMPRESSOR
UNIT GROUND

RK-115 OR 230 VOLT- P.S.C.

2nd RUN CAPACITOR
(IF USED)

RUN CAPACITOR

INTERNAL
OVERLOAD

115 OR 230 VOLT - SCHEMATIC WIRING
DIAGRAM - PSC REF. DWG.#MD-472-6

RK

3D,VNX10

ENGLISH

Q.A. SYMBOLS

- ★ = CATEGORY I
- ▲ = CATEGORY II
- = CATEGORY III
- = CATEGORY IV

LT	LC	CHANGE	DATE
EC05995	ORIENTATION CHANGED FOR START, RUN & 24JUL18	RP	COMMON CONNECTIONS
A 2F		REL	EC06058 ATC

DWG NO.	DESCRIPTION
DERK04	ELECTRICAL HOOK-UP DRAWING
SCALE 1=1 & NOTED	THIS PRINT SUPERSEDES ALL PRINTS PRIOR TO
MATERIAL	TECUMSEH PRODUCTS CO. ANN ARBOR, MICHIGAN